

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
District Disaster Response & Fire
Officer
Andhra Pradesh, West Godavari

To:
DISTRICT EDUCATIONAL
OFFICER, ELURU,

File No: 31279/WGV/DFO/2026, Date:20/04/2026

Occupancy NoC RC Number: 614/A1/2011

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **VASAVI IDEAL PUBLIC SCHOOL, represented by VASAVI EDUCATIONAL ACADEMY, CHINA TADEPALLI, TADEPALLI (M) PIN-534101** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 614/A1/2011, Dt.27/04/2016
 4. Renewal NOC For Occupancy 614/A1/2011, Dt.30/07/2021
 5. Online Application for Renewal NOC of VASAVI EDUCATIONAL ACADEMY, CHINA TADEPALLI, TADEPALLI (M) PIN-534101 - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 17-04-2026.

-- x --

The Management of VASAVI IDEAL PUBLIC SCHOOL, represented by VASAVI EDUCATIONAL ACADEMY, CHINA TADEPALLI, TADEPALLI (M) PIN-534101 has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.62800/- vide challan No. 11009042642026, Dated 09/04/2026 at ONLINE PAYMENT, ONLINE PAYMENT.

VASAVI IDEAL PUBLIC SCHOOL

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **VASAVI EDUCATIONAL ACADEMY CHINA TADEPALLI, TADEPALLI (M)**



PIN-534101, subject to the following conditions.

Sl	As Builder	As Occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This is Only for Fire Safety Point of View.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4. This Periodical Renewal Fire Certificate is valid from 20/04/2026 to 19/04/2028.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number	Challan Date	Challan Amount
11009042642026	2026-04-09	62800

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

The Inspection Committee consisting of FSI0 Tadepalligudem Fire Station Stated in his Report: The management has constructed a non-multistoried educational building comprising Ground + two (02) upper floors, with a height of 10.00 meters, in a total plot area of 8093.88 sq. meters and a total built-up area of 6276.00 sq. meters. The management has provided two (02) staircases with a total width of 2.75 meters as means of escape. as

against the required width of 5.25 meters. In this regard, the management has submitted an affidavit undertaking to provide the deficit width of 2.50 meters by constructing two (02) additional staircases (one at the southeast side and one at the northeast side) within a period of three (03) months. Further, the management has provided firefighting equipment in accordance with the National Building Code-2016, and the same was tested at the time of inspection and found to be in good working condition. The management has also remitted an amount of Rs. 62,800/- towards renewal fee for a period of two (02) years.

The Management is requested that, The Provided Fire Fighting equipment should be maintained always in good working Condition.

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సురక్షిత పాఠశాలలు, సురక్షిత మైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."



Your Sincerely,

[Signature]
20/04/2026

District Disaster Response & Fire Officer,
West Godavari District

In case of emergency, please call 101 or 08818-221299 or 9963725443

Copy to Management VASAVI EDUCATIONAL ACADEMY, VASAVI EDUCATIONAL ACADEMY

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned